



Demand Side Management & Audit Review

April 2012

Keno Hill Project Overview



KEY Reasons for Involvement

2011 Demand Side Management Energy Audit

- Mutually beneficial partnership between YEC & Alexco
- Identified areas which allow Alexco to:
 - ✓ Reduce peak usage
 - ✓ Reduce total energy usage
 - ✓ Identify possible efficiencies
 - ✓ Further reduce energy footprint




Study Scope

<p>1.</p> <p>Observation of Keno Hill Project operational procedures</p>	<p>2.</p> <p>Comparison of other projects to Keno Hill Project</p>	<p>3.</p> <p>Analysis of utilization rates & operational parameters</p>	<p>4.</p> <p>Final report & recommendations to Alexco & YEC</p>
<p>1 week at site</p> <p>Off-site consulting work</p>	<p>Database comparison for efficiency gains</p>	<p>Large equipment such as: air compressors, crushers, blower, ball mill ...</p>	<p>Operational recommendations & capital projects</p>

Typical Energy Profile

- Base Load = Daily Steady State Operations
- All infrastructure must be sized to peak load
- Peaks are associated with ore crushing operations





Recommendations of Demand Side Audit

1. Instillation of an ammeter in Mill operators cab
2. Convert plant lighting to T5 HO fluorescents & LED's for outdoors
3. Re-commission mill air system
4. Initiate compressed air leak reduction program
5. Commission the air blower inlet modulation
6. Re-apply variable frequency drives to Mine ventilation
7. Optimize plant process thru program logic controller
8. Install electrical sub-metering for Mine
9. kWh per tonne as performance measure
10. Install capacitors on the 600V Mill




Status of Recommendations

- ✓ Investigation of alternate lighting options (LED's) - in progress
- ✓ Mill compressed air system has been re-commissioned
- ✓ Ongoing air leak reduction program at Mill & Mine
- ✓ Additional variable frequency drives have been installed
- ✓ Program logic control on filter presses implemented
- ✓ Evaluation of site power distribution & metering options - in progress
- ✓ Cost benefit analysis & design of power factor correction unit for the Mill – in progress

Power Factor (PF)

- Power Factor is a measure of how effectively the power is being used and is a ratio of “active power” used to the “apparent power” required which is a combination of both active power & reactive power
- 0.85 for normal operations
- 0.75 for peak loading conditions
 - For every unit of power required to run upwards of 15-20% more power needs to be provided
- 0.95 – 0.98 PF with correction



- **$PF = \text{Active Power} / \text{Apparent Power}$**



Future Considerations

- Increased use of variable frequency drives on motors
- Power factor correction studies
- Energy measuring devices
- Alternative lighting sources
- Proper equipment sizing & selection
- Ongoing evaluation of operational practices



Alexco Contact Info

Peter Johnson – Construction Manager

Vancouver Head Office
1150 – 200 Granville St.
Vancouver, BC V6C 1S4
T: 604-633-4888
F: 604-633-4887

Whitehorse Office
#3 Calcite Business Centre
151 Industrial Road
Whitehorse, Yukon Y1A 2V3
T: 867-633-4881
F: 867-633-4882

Keno Hill Silver District
Elsa, Yukon Y0B 1G0
T: 867-996-2330
F: 867-995-2600