






Danger

MINIMUM REQUIREMENTS FOR UNQUALIFIED WORKERS AND/OR EQUIPMENT OPERATING NEAR OVERHEAD POWER LINES



Purpose: These minimum requirements are for your protection and safety. Contact with power lines is extremely dangerous and could result in death.

- 1) Danger Zone (unknown voltage) Equipment shall not work within 7 meters (23 feet) of any overhead power line without notifying the local **Yukon Energy** office.
- 2) Prohibited Zone of identified voltages (confirmed by **Yukon Energy**).
 - a) No unqualified worker or equipment shall encroach on the Prohibited Zone.
 - b) Equipment is not to operate closer than 7 metres (23 feet) from our power lines. If you must work closer than 7 metres, call Yukon Energy to have the line de-energized.
- 3) Power lines must be de-energized if workers or equipment cannot maintain Prohibited Zone clearances, unless under the **DIRECT** supervision of a Yukon Energy qualified employee.
- 4) Work around power lines is to be done during daylight hours only.
- 5) Workers are recommended to supply and install a minimum of two Danger High Voltage signs as shown above or Danger Overhead Power Line signs shown above.
- 6) Before work or other activity is commenced in the vicinity of an overhead power line, contact the local **Yukon Energy** office to establish the safe limits of approach distances.
- 7) No earth or other materials shall be placed under or adjacent to an overhead power line if it reduces the clearance above ground for the power line.
- 8) No person shall excavate or perform similar work in the vicinity of an overhead power line if it reduces the support for the power line.

Any violation could lead to sanctions under the Yukon OH&S Act and Regulations.


If you have questions about clearance and are working in Yukon Energy service areas stay clear and call 1-800-676-2843.





Danger

MINIMUM REQUIREMENTS FOR UNQUALIFIED WORKERS AND/OR EQUIPMENT OPERATING NEAR UNDERGROUND CABLES



Purpose: These minimum requirements are for your protection and safety. Contact with underground power cables is extremely dangerous and could result in death.

- 1) You must **CALL BEFORE YOU DIG** to ascertain whether underground power cables are located at or near the excavation site. For Yukon Energy service areas call 1-800-676-2843. For other underground facilities, contact the operator of the facility.
- 2) Prior to any ground disturbance or excavation activity, **Yukon Energy** will identify and mark any underground cables that are located near the utility controlled excavation area.
- 3) The person responsible for an excavation must make sure that no excavation work is undertaken within **1 m** of any underground power cables unless:
 - a) The excavation work is done under the control of **Yukon Energy**, and
 - b) The excavation work method is approved by **Yukon Energy**.

If you accidentally dig into an underground power cable in a Yukon Energy service area, stay clear and call 1-800-676-2843.

